

General Workplace Safety & Health Inspection Checklist: Location: ______ Date: _____ Date: ______ FORM 8.90A

All A				T - u -						
All Areas				All Areas						
	'				☐ Shelving that exceeds the 4:1 ratio must be secured in place. i.e. a shelf that is 5					
	, , ,				feet high and 1 foot wide must be secured whereas a shelf that is 3 feet high					
	☐ All Fire Extinguishers are fully charged.				and 1 foot wide does not need to be secured. Stacked items must not be at risk of falling and must have a 12-14" clearance to					
	☐ Electrical outlets must not have any visible damage or be covered with tape.			the ceiling (18" if near a sprinkler head).						
	Fire separations must not be compromised e.g. ceiling tiles have not been removed.			☐ Carpets/mats are not lifting or have loose seams.						
	Light fixtures must be fitted with pro	per l	light covers.							
	Entrances, Exits, Hallways &	Traditional Classrooms			Main Office		Boiler Room / Custodian Room			
	Storage Rooms									
	Approaches to stairway, hallways & exits are kept free from ice, snow & obstructions. Stairways are equipped with handrails. Exit signs are highly visible. Panic hardware on all fire exit doors is in working order. Stairways, hallways & stairwells are adequately illuminated. Stair treads, mats, must not present a tripping hazard. Paper on hallway walls does not exceed 5% of the total wall surface; all materials must be fastened at all corners and placed on a bulletin board.		Paper on each wall does not exceed 20% of total wall surface. Tables, chairs, desks & other equipment are arranged to conform to good safety practices. Paper Cutters are not accessible to students without supervision. Chemical or Cleaning Products are not accessible to students without supervision. Ventilation units are clear (no items stacked on top).		A fully stocked First Aid Kit is located nearby in a highly visible location (First Aid Sign). A current comprehensive emergency preparedness plan is available. The building fire plan is current, located in a highly visible location and easily accessible to emergency personnel (fire department). Office furniture allows the user to work in an ergonomically correct posture. Admin. Medication cabinet is locked; sign off sheet current. W S &H Bulletin Board is readily accessible & current information is posted. Monthly Fire Drill Log is readily available.		The floor must be kept clear of slip & trip hazards. Emergency shut-offs, fire pull stations and fire extinguisher locations are highly visible. Certificates of annual inspections (e.g. boiler) are visible & current. Guards are in place over belts & rotating shafts on any equipment. Electrical panel must be accessible at all times with a clear space around the front & sides of panels. Hand tools are stored when not in use. Personal Protective Equipment is supplied and is in good condition. All chemicals are stored and labeled according to standards. Eyewash station is located within a ten second walk. Storage shelves are firmly constructed to prevent tipping. Inspection reports are readily available.			

Industrial Arts / Power Mechanics	Science Classroom	Food Services	Gym
There is a charged fire extinguisher mounted near the exit. Fire separations must not be compromised e.g. no missing	Emergency equipment including eye wash station, fire blankets, fire pull stations are highly visible (signs posted).	All appliances must be equipped with safety guards. Hand power appliances must be stored when not in use.	Entrances/Exit routes must be unobstructed, no door knobs, protruding handles on gym side of door.
ceiling tiles. Emergency shut off, fire pull stations and fire extinguisher locations are highly visible.	A chemical fume hood is located in the room (and not used for chemical storage). A locked Flammable Cabinet is	Dangerous areas must be placarded with caution signs e.g. Hot Surfaces. Emergency shut offs must be	Meshing on lights secure. All wall mounted clocks are caged. Floor sockets/plates are covered and flush to the floor. Plates are in good
Safe work zones around machines must be indicated by yellow paint.	available for flammable chemicals. A Non-Metal Cabinet is available for	unobstructed and clearly identified by a sign.	condition. All outlets & switches which pose an
All machines are equipped with safety guards. Hand tools must be stored when	Acid Storage. All chemicals are labeled according to SDS requirements.	Knives are stored safely. All major appliances are plugged into CSA approved ground	unreasonable hazard must be padded or flush with wall surface. Top and supports on benches; must be
not in use. All machines must be placarded	A SDS is available for all WHMIS controlled products.	outlets. All food is stored in sealed	free from cracks & splinters. Mats; should be free of tears &
with caution signs including Safe Work Procedures.	All wiring is in good condition (no fraying, tape etc.)	vermin-proof containers. All wiring must be in good	wearing. Ropes, cargo nets & climbing
Extension cords must not be used as permanent wiring. All wiring must be in good	Personal Protective Equipment is supplied, in good condition when used. A safety shower is located in the room	condition (no fraying, tape etc.) A fully stocked first aid kit is located in the room in a highly	apparatus; ropes & wires in good condition. A fully stocked first aid kit is located in
condition (no fraying, tape, etc.). All machines must be interlocked	if required by SDS for chemicals used in the room.	visible location (sign). Kitchen counter surfaces and	the room in a highly visible location (sign).
to a keyed electrical shut-off. Eyewash is located in the room (or within a 10 second walk).	A spill control kit and procedures are in place. The natural gas line is locked off when	cutting boards do not have cracks and or chips. Air /ventilation system working	Basketball hoop, nets appears to be in good condition.
A fully stocked first aid kit is located in the room in a highly visible location (sign).	it is not in use. The natural gas shut-off location is identified with a sign.	properly	
A current MSDS Binder is readily available for all chemicals.	A fully stocked First Aid Kit and Burn Kit are available.		
Air hoses, cables etc. are stored so as to not constitute a tripping hazard.			
Air/ventilation system is functioning.			